

Температурный график тепловых сетей 150/70 °С со срезкой на 115 °С

| Т н.в. | Т 1 | Т 2 | Температура теплоносителя в подающем трубопроводе с поправкой на ветер, °С | | | | | | | | | | | | | | | | | |
|--------|-----|-----|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| | | | Скорость ветра, м/с | | | | | | | | | | | | | | | | | |
| | | | 10 | 12 | 14 | 16 | 18 | 20 | 22 | 24 | 26 | | | | | | | | | |
| 8 | 70 | 45 | | | | | | | | | | | | | | | | | | |
| 7 | 70 | 44 | | | | | | | | | | | | | | | | | | |
| 6 | 70 | 44 | | | | | | | | | | | | | | | | | | |
| 5 | 70 | 43 | | | | | | | | | | | | | | | | | | |
| 4 | 70 | 42 | | | | | | | | | | | | | | | 71 | 72 | 73 | |
| 3 | 70 | 41 | | | | | 71 | 72 | 73 | 74 | 75 | 76 | | | | | | | | |
| 2 | 72 | 42 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84 | 85 | 86 | 87 | 88 | 89 |
| 1 | 75 | 43 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84 | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 |
| 0 | 78 | 45 | 78 | 79 | 81 | 82 | 83 | 84 | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 |
| -1 | 81 | 46 | 81 | 83 | 84 | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 |
| -2 | 84 | 47 | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 | 101 | 102 |
| -3 | 87 | 49 | 88 | 89 | 90 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 | 101 | 102 | 103 | 104 | 105 | 106 |
| -4 | 90 | 50 | 91 | 92 | 94 | 95 | 96 | 97 | 98 | 99 | 100 | 101 | 102 | 103 | 104 | 105 | 106 | 107 | 108 | 109 |
| -5 | 93 | 51 | 94 | 95 | 97 | 98 | 99 | 100 | 101 | 102 | 103 | 104 | 105 | 106 | 107 | 108 | 109 | 110 | 111 | 112 |
| -6 | 96 | 53 | 97 | 99 | 100 | 101 | 103 | 105 | 106 | 107 | 108 | 109 | 110 | 111 | 112 | 113 | 114 | 115 | 116 | 117 |
| -7 | 99 | 54 | 100 | 102 | 103 | 105 | 106 | 108 | 109 | 110 | 111 | 112 | 113 | 114 | 115 | 116 | 117 | 118 | 119 | 120 |
| -8 | 102 | 55 | 103 | 105 | 106 | 108 | 110 | 111 | 112 | 113 | 114 | 115 | 116 | 117 | 118 | 119 | 120 | 121 | 122 | 123 |
| -9 | 105 | 56 | 106 | 108 | 110 | 111 | 113 | 114 | 115 | 116 | 117 | 118 | 119 | 120 | 121 | 122 | 123 | 124 | 125 | 126 |
| -10 | 108 | 57 | 109 | 111 | 113 | 114 | 115 | 116 | 117 | 118 | 119 | 120 | 121 | 122 | 123 | 124 | 125 | 126 | 127 | 128 |
| -11 | 111 | 59 | 112 | 114 | 115 | 116 | 117 | 118 | 119 | 120 | 121 | 122 | 123 | 124 | 125 | 126 | 127 | 128 | 129 | 130 |
| -12 | 114 | 60 | 115 | 116 | 117 | 118 | 119 | 120 | 121 | 122 | 123 | 124 | 125 | 126 | 127 | 128 | 129 | 130 | 131 | 132 |
| -13 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -14 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -15 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -16 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -17 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -18 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -19 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -20 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -21 | 115 | 62 | | | | | | | | | | | | | | | | | | |
| -22 | 115 | 62 | | | | | | | | | | | | | | | | | | |

Теплоснабжающая организация

Потребитель

_____ Ф.И.О.
 М.П.
 " ____ " _____ 20__ г.

_____ Ф.И.О.
 М.П.
 " ____ " _____ 20__ г.